

Additional Motor Data

HP: _____ Phase: 1Ø 3Ø Rated Voltage: _____
Starting Current: _____ Full Load Current: _____ NEMA Code: _____
% PF at Full Load: _____ % Efficiency at Full Load: _____
% PF at Locked Rotor: _____ Motor Start Type: Soft Start VFD
For Soft Start Only
Starting Line Resistance: _____ Starting Line Reactance: _____
% Transformer Tap: _____ Use Delta Soft Start? Yes No

Single-phase motors over 10 HP require Cooperative approval. All motors over 50 HP require a soft start.

Additional Motor Data

HP: _____ Phase: 1Ø 3Ø Rated Voltage: _____
Starting Current: _____ Full Load Current: _____ NEMA Code: _____
% PF at Full Load: _____ % Efficiency at Full Load: _____
% PF at Locked Rotor: _____ Motor Start Type: Soft Start VFD
For Soft Start Only
Starting Line Resistance: _____ Starting Line Reactance: _____
% Transformer Tap: _____ Use Delta Soft Start? Yes No

Single-phase motors over 10 HP require Cooperative approval. All motors over 50 HP require a soft start.