



- A. 3' - Doors, porches, fire escapes, windows, and balconies
- B. 3' - Overhang above roof
- C. 12' - Pedestrian and restricted traffic areas, except where attachment at building does not permit 12' clearance:  
 10.5' - Voltage limited to 300V to ground for service drops and drip loops  
 10' - Voltage limited to 150V to ground for service drop and drip loops
- D. 16' - Driveways, alleys, and parking lots. Exception: residential driveways where only attachment at building does not permit 15' clearance:  
 12.5' - Voltage limited to 300V to ground for service drops  
 10.5' - Voltage limited to 300V to ground for drip loops  
 12' - Voltage limited to 150V to ground for service drops  
 10' - Voltage limited to 150V to ground for drip loops
- E. 16' - Streets, roads, highways, and areas with truck traffic

	 <b>DANGER</b>
	HAZARD OF ELECTRICAL SHOCK OR BURN IF COVER IS REMOVED. SERVICE BY UTILITY AUTHORIZED PERSONNEL ONLY

UPSHUR RURAL ELECTRIC COOP. CORP.  
P.O. BOX 70 GILMER, TX. 75644

**OVERHEAD  
SERVICE-DROP  
CLEARANCES**

DRAWN BY	JZ	DRAWING NO.	OHS-4	REV	1
APPROVED BY					
SCALE	None	DATE DRAWN	6/19/17	SHEET	1 OF 1